



United States Steel Corporation
Clairton Works
400 State Street
Clairton, PA 15025

February 28, 2013

Ms. Adina Savage
Allegheny County Health Department
Department of Air Quality
301 Thirty-Ninth Street
Pittsburgh, PA 15201

Subject: USS Reference Number: 13-0052
ACHD Reference Number: 15603
"B" Battery Igniter Flare
USS Clairton Works

Dear Adina Savage,

The attached form confirms our verbal report of the subject incident and satisfies the requirements of paragraph IV.8 of the Title V operating permit #0052 as issued on March 27th 2012.

I certify that based on the information and belief formed after reasonable inquiry, the statements and information in this document are true, accurate, and complete. Any questions concerning this matter should be referred to Coleen M. Davis at 412-233-1015.

Sincerely,

Thomas E. Schumacher
Acting Plant Manager
Clairton Works

CC: James W. Hagedorn (USEPA)

ED_002508A_00000721-00001

NOTICE OF OUTAGE OF EQUIPMENT
ARTICLE XXI - SECTION 2108.1

1. USS Reference Number: 13-0052
ACHD Reference Number: 15603
2. Date & Time of Breakdown: Date: 02/27/13 Time: 0530 hours
3. Company Name: U.S. Steel Corporation - USS Clairton Works
4. Specific Equipment Involved or Affected: "B" Battery Igniter Flare
5. BAPC Permit Number (if applicable):
6. Location: Clairton, PA
7. Nature and cause of breakdown: The "B" Battery Igniter Flare was unavailable for service due to an extinguished pilot.
8. Identification of Emissions:
 - A. Type(s) (CO, NOX, SO₂, Particulates, Hydrocarbons, etc.)
No environmental impact.
 - B. Toxic qualities of each type (including its qualities as an irritant, and its potential for causing illness, disability, or mortality). N/A.
 - C. Amount of each type emitted (or likely to be emitted).
N/A.
9. Measures taken (or to be taken) to minimize length of breakdown and amount of emissions, including shutdown or curtailment (or why it is impossible or impractical to do so).
The pilot was relit and the Igniter Flare was available for service.
10. Facility back in operation - Date: 02/27/13 Time: 1205 hours

Reviewed by Coleen M. Davis Date 2-28-13
Coleen M. Davis
Senior Environmental Control Engineer Phone: 412-233-1015